

**SECTION 079200****JOINT SEALERS****PART 1 GENERAL****1.1 GENERAL REQUIREMENTS**

- A. Work of this Section, as shown or specified, shall be in accordance with the requirements of the Contract Documents.

**1.2 SECTION INCLUDES**

- A. The Work of this Section includes all labor, materials, equipment, and services necessary to complete the joint sealers work as shown on the drawings and/or specified herein, including, but not necessarily limited to, the following:
  - 1. Exterior wall joints not specified to be sealed in other Sections of work.
  - 2. Interior wall joints not specified to be sealed in other Sections of work, including caulking to fill between architectural woodwork and any wall, floor and/or ceiling imperfections.
  - 3. Control and expansion joints in walls.
  - 4. Joints at wall penetrations.
  - 5. Joints between items of equipment and other construction.
  - 6. All other joints required to be sealed to provide a positive barrier against penetration of air and moisture.

**1.3 RELATED SECTIONS**

- A. Existing Roof Work - Section 075113.
- B. Firestops and Smoke seals - Section 078413.
- C. Glass and Glazing - Section 088000, for glazing sealants.
- D. Gypsum Board Assemblies - Section 092116, for sealants within drywall construction.
- E. Ceramic Tiling - Section 093013, for sealant at tile work.

**1.4 QUALITY ASSURANCE**

- A. Qualification of Installers: Use only personnel who are thoroughly familiar, skilled and specially trained in the techniques of sealant work, and who are completely familiar with the published recommendations of the sealant manufacturer.
- B. Pre-Construction Field Adhesion Testing: Before installing elastomeric sealants, field test their adhesion to project joint substrates according to the method in ASTM C 794 and C 1521 that is appropriate for the types of Project joints.

- C. Perform testing per ASTM C 1248 on interior and exterior sealants to determine if sealants or primers will stain adjacent surfaces. No sealant work shall start until results of these tests have been submitted to the Commissioner and he has given his written approval to proceed with the work.

#### **1.5 SUBMITTALS**

- A. Shop Drawings: Submit shop drawings showing all joint conditions, indicating relation of adjacent materials, all sealant materials (sealant, bond breakers, backing, primers, etc.), and method of installation.
  - 1. Submit joint sizing calculations certifying that movement capability of sealant is not being exceeded.
- B. Samples: Submit the following:
  - 1. Color samples of sealants, submit physical samples (not color chart).
  - 2. Sealant bond breaker and joint backing.
- C. Product Data: Submit manufacturer's technical information and installation instructions for:
  - 1. Sealant materials, indicating that material meets standards specified herein.
  - 2. Backing rods.
- D. Submit manufacturer's certification as required by Article 1.6 herein.
- E. Submit results of testing required in Article 1.4 herein.

#### **1.6 MANUFACTURER'S RESPONSIBILITY AND CERTIFICATION**

- A. Contractor shall require sealant manufacturer to review the Project joint conditions and details for this Section of the work. Contractor shall submit to the Commissioner written certification from the sealant manufacturer that joints are of the proper size and design, that the materials supplied are compatible with adjacent materials and backing, that the materials will properly perform to provide permanent watertight, airtight or vaportight seals (as applicable), and that materials supplied meet specified performance requirements.

#### **1.7 ENVIRONMENTAL CONDITIONS**

- A. Temperature: Install all work of this Section when air temperature is above forty (40) degrees F. and below eighty (80) degrees F., unless manufacturer submits written instructions permitting sealant use outside of this temperature range.
- B. Moisture: Do not apply work of this Section on surfaces which are wet, damp, or have frost.

#### **1.8 PRODUCT HANDLING**

- A. Protection: Use all means necessary to protect the materials of this Section, before, during and after installation and to protect the installed work and materials of all other trades.

- B. Replacements: In the event of damage, immediately make all repairs and replacements necessary.
- C. Storage
  - 1. Store sealant materials and equipment under conditions recommended by their manufacturer.
  - 2. Do not use materials stored for a period of time exceeding the maximum recommended shelf life of the material.
  - 3. Material shall be stored in unopened containers with manufacturers' name, batch number and date when shelf life expires.

## 1.9 WARRANTY

- A. Provide a written, notarized warranty from the manufacturer stating that the applied sealants shall show no material failure for a period of ten (10) years.
- B. Contractor to provide a written, notarized, warranty stating that the applied sealants shall show no failure due to improper installation for a period of one (1) year.
- C. Warranty shall be in a form acceptable to the City of New York and executed by an authorized individual.
- D. Include in warranty provision, agreement to repair and/or replace, at Contractor's expense, sealant defects which develop during warranty period, because of faulty labor and/or materials.

## PART 2 PRODUCTS

### 2.1 SEALANT MATERIALS

- A. Exterior Wall Sealant: Provide one (1) part non-sag sealant equal to No. 790 or 795 made by Dow Corning, "Silpruf SCS 2000" or "LM SCS 2700" made by G.E. or "Spectrem 1" or "Spectrem 3" made by Tremco or "Sonolastic 150" by Sonneborn conforming to the minimum standards of ASTM C 920, Type S, Grade NS, Class 50.
- B. Interior Sealant: Provide a one (1) part acrylic based sealant conforming to ASTM C 834, equal to "AC-20+ Silicone" made by Pecora or equal made by Tremco.
- C. Colors: Custom colors of sealants as selected by the Commissioner.

### 2.2 MISCELLANEOUS MATERIALS

- A. Back-Up Materials: Provide back-up materials and preformed joint fillers, non-staining, non-absorbent, compatible with sealant and primer, and of a resilient nature, equal to "HBR" made by Nomaco Inc. or approved equal, twenty-five (25) percent wider than joint width. Materials impregnated with oil, bitumen or similar materials shall not be used. Provide back-up materials only as recommended by sealant manufacturer in writing.
- B. Provide bond breakers, where required, of polyethylene tape as recommended by manufacturer of sealant.

- C. Provide primers recommended by the sealant manufacturer for each material to receive sealant. Note that each exterior joint must be primed prior to sealing.
- D. Provide solvent, cleaning agents and other accessory materials as recommended by the sealant manufacturer.
- E. Materials shall be delivered to the job in sealed containers with manufacturer's original labels attached. Materials shall be used per manufacturer's printed instructions.

### **PART 3 EXECUTION**

#### **3.1 INSPECTION**

- A. Examine the areas and conditions where joint sealers are to be installed and correct any conditions detrimental to the proper and timely completion of the work. Do not proceed with the work until unsatisfactory conditions are corrected to permit proper installation of the work.

#### **3.2 INSTALLATION**

- A. Sealant Installation Standard: Comply with instructions and recommendations of the manufacturer and in accordance with ASTM C 1193 for use of joint sealants as applicable to materials, applications and conditions required by this Project where more stringent installation requirements are specified herein, such requirements shall apply.
- B. Sample Section of Sealant
  - 1. During sealant installation work in exterior wall, the manufacturer of sealant shall send his representative to the site, under whose supervision a section of the wall (used as "control section") shall be completed for purposes of determining performance characteristics of sealant in joints. Commissioner shall be informed of time and place of such installation of control section.
  - 2. Control section shall be installed according to specification given herein and shall not be considered as acceptable until written acceptance is provided by the Commissioner.
  - 3. Accepted control section shall be standard to which all other sealant work must conform.
- C. Supervision: The Contractor shall submit to the Commissioner written certification from the sealant manufacturer that the applicators have been instructed in the proper application of their materials. The Contractor shall use only skilled and experienced workmen for installation of sealant.
- D. Apply sealant under pressure with a hand or power actuated gun or other appropriate means. Gun shall have nozzle of proper size and provide sufficient pressure to completely fill joints as detailed. Neatly point or tool joint to provide the contour as indicated on the drawings.
- E. Preparation and Application
  - 1. Thoroughly clean all joints, removing all foreign matter such as dust, oil, grease, water, surface dirt and frost. Sealant must be applied to the base surface. Previously applied film must be entirely removed.

2. Stone, masonry and concrete surfaces to receive sealant shall be cleaned where necessary by grinding, water blast cleaning, mechanical abrading, or combination of these methods as required to provide a clean, sound base surface for sealant adhesion.
  - a. Do not use any acid or other material which might stain surfaces.
  - b. Remove laitance by grinding or mechanical abrading.
  - c. Remove loose particles present or resulting from grinding, abrading, or blast cleaning by blowing out joints with compressed air, oil and water free, or vacuuming joints prior to application of primer or sealant.
3. Clean non-porous surfaces such as metal and glass chemically. Remove protective coatings on metallic surfaces by solvent that leaves no residue and is compatible with sealant. Use solvent and wipe dry with clean, dry lint free paper towels. Do not allow solvent to air dry without wiping. Clean joint areas protected with masking tape or strippable films as above after removal of tape film.
4. Do not seal joints until they are in compliance with drawings, or meet with the control section standard.
5. Joint Size and Sealant Size: Joints to receive sealant shall be at least 1/4" wide. In joint 1/4" to 3/8" wide, sealant shall be 1/4" deep. In joints wider than 3/8" and up to 1" wide, sealant depth shall be one half the joint width. For joints wider than 1", sealant depth shall be as recommended by the sealant manufacturer. Depth of joint is defined as distance from outside face of joint to closest point of the filler.
6. Primer: Thoroughly clean joints and apply primer to all surfaces that will receive sealant. Apply primer on clean, dry surfaces, and prior to installation of joint backing. Completely wet both inner faces of the joint with primer. Mask adjacent surfaces of joint with non-staining masking tape prior to priming. Apply primer with clean brush and only when temperature is above 45 deg. F.
7. Joint Backing: In joints where depth of joint exceeds required depth of sealant, install joint backing (after primer is dry) in joints to provide backing and proper joint shape for sealant. Proper shape for sealant is a very slight "hourglass" shape, with back and front face having slight concave curvature. Use special blunt T-shaped tool or roller to install joint backing to the proper and uniform depth required for the sealant. Joint backing shall be installed with approximately twenty-five (25) percent compressions. Do not stretch, twist, braid, puncture, or tear joint backing. Butt joint backing at intersections.
8. Bond Breaker: Install bond breaker smoothly over joint backing so that sealant adheres only to the sides of the joint and not backing.
9. Sealant Application: Apply sealant in accordance with the manufacturer's application manual and manufacturer's instructions, using hand guns or pressure equipment, on clean, dry, properly prepared substrates, completely filling joints to eliminate air pockets and voids. Mask adjacent surfaces of joint with non-staining masking tape. Force sealant into joint in front of the tip of the "caulking gun" (not pulled after it) and force sealant against sides to make uniform contact with sides of joint and to prevent entrapped air or pulling of sealant off of sides. Fill sealant space solid with sealant.
10. Tooling: Tool exposed joints to form smooth and uniform beds, with slightly concave surface conforming to joint configuration per Figure 4A in ASTM C 1193. Finished joints shall be straight, uniform, smooth and neatly finished. Remove

masking tape immediately after tooling of sealant and before sealant face starts to "skin" over. Neatly remove any excess sealant from adjacent surfaces of joint, leaving the work in a neat, clean condition.

11. Replace sealant which is damaged during construction process.

**END OF SECTION**