

SECTION 104416**FIRE EXTINGUISHERS AND CABINETS****PART 1 GENERAL****1.1 GENERAL REQUIREMENTS**

- A. Work of this Section, as shown or specified, shall be in accordance with the requirements of the Contract Documents.

1.2 SECTION INCLUDES

- A. The Work of this Section includes all labor, materials, equipment, and services necessary to complete the fire extinguishers and cabinets as shown on the drawings and/or specified herein.

1.3 RELATED SECTIONS

- A. Gypsum Board Assemblies - Section 092116.
- B. Division 21 for fire suppression systems.

1.4 QUALITY ASSURANCE

- A. Provide portable fire extinguishers, cabinets and accessories by one manufacturer.
- B. UL-Listed Products: Provide new portable fire extinguishers which are UL-listed and bear UL "Listing Mark" for type, rating, and classification of extinguisher indicated.

1.5 SUBMITTALS

- A. Product Data: Submit manufacturer's technical data and installation instructions for all portable fire extinguishers required. For fire extinguisher cabinets include roughing-in dimensions, and details showing mounting methods, relationships to surrounding construction, door hardware, cabinet type and materials, trim style and door construction, style and materials. Where color selections by Commissioner are required, include color charts showing full range of manufacturer's standard colors and designs available.
- B. Samples: Submit samples, 6" square, of each required finish. Prepare samples on metal of same gauge as metal to be used in the work. Where normal color variations are to be expected, include 2 or more units in each sample showing the limits of such variations.

PART 2 PRODUCTS**2.1 MANUFACTURERS**

- A. Subject to compliance with requirements, provide products of one of the following or an approved equal:
 - 1. J. L. Industries.
 - 2. Larsen's Mfg. Co.

3. Potter Roemer.

2.2 EXTINGUISHERS

- A. General: Provide fire extinguishers for each extinguisher cabinet and other locations indicated, in colors and finishes selected by Commissioner from manufacturer's standard which comply with requirements of governing authorities.
- B. Abbreviations indicated below to identify extinguisher type related to UL classification and rating system and not necessarily to type and amount of extinguishing material contained in extinguisher.
- C. Multi-Purpose Dry Chemical Type: UL rated 2A-10B:C, 5 lb. nominal capacity, in enameled steel container, for Class A, Class B and Class C fires.

2.3 MOUNTING BRACKETS

- A. Provide manufacturer's standard bracket designed to prevent accidental dislodgment of extinguisher, of proper size for type and capacity of extinguisher specified, in manufacturer's standard enamel finish; color to match extinguisher.

2.4 CABINETS

- A. Type and Style: Fire extinguisher cabinets shall be metal, recessed, with plexiglass panel, sized to fit within the partition or wall depth. Provide fire rated cabinets within fire rated partitions.
- B. Color: Fire extinguisher cabinets shall be factory pre-finished with baked enamel in the colors selected by the Commissioner from the standard range of colors of the selected manufacturer.
- C. Design is based on "Model G-2409-R1" of Larsen's Mfg. Co. Other manufacturers noted herein may substitute their equivalent cabinet upon acceptance by the Commissioner.

PART 3 EXECUTION**3.1 INSPECTION**

- A. Examine the areas and conditions where fire extinguishers and cabinets are to be installed and correct any conditions detrimental to the proper and timely completion of the work. Do not proceed with the work until unsatisfactory conditions are corrected to permit proper installation of the work.

3.2 INSTALLATION

- A. Install items included in this Section in locations indicated and at heights to comply with applicable regulations of governing authorities.
 - 1. Prepare recesses in walls for fire extinguisher cabinets as required by type and size of cabinet and style of trim and to comply with manufacturer's instructions.
 - 2. Securely fasten mounting brackets and fire extinguisher cabinets to structure, square and plumb, to comply with manufacturer's instructions.

- B. Where exact location of cabinets and bracket-mounted fire extinguishers is not indicated, locate as directed by the Commissioner.

3.3 IDENTIFICATION

- A. Identify fire extinguisher in cabinet with lettering spelling "FIRE EXTINGUISHER" painted on door by silk-screen process. Provide lettering on door as selected by Commissioner from manufacturer's standard letter sizes, styles, colors and layouts.
- B. Identify bracket-mounted extinguishers with red letter decals spelling 'FIRE EXTINGUISHER' applied to wall surface. Letter size, style and location as selected by the Commissioner.

3.4 SERVICE

- A. Determine the approximate completion date of the work and then inspect, charge, and tag the fire extinguishers at a date not more than 10 days before or not less than one day before actual completion date of the work.

END OF SECTION

This page intentionally left blank.