

SECTION 09 51 13

ACOUSTICAL PANEL CEILINGS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general conditions of Contract, including General and Supplementary Conditions and Divisions-1 Specification sections apply to work of this section.

1.2 SUMMARY

A. Section Includes:

1. Acoustical ceiling panels.
2. Exposed grid suspension system.
3. Wire hangers, fasteners, main runners, cross tees, and wall angle moldings.

B. Related Sections:

1. Section 09 29 00 - Gypsum Board
2. Divisions 23 - HVAC
3. Division 26 - Electrical Work

C. Alternates

1. Prior Approval: Unless otherwise provided for in the Contract documents, proposed product substitutions may be submitted no later than TEN (10) working days prior to the date established for receipt of bids. Acceptability of a proposed substitution is contingent upon the Architect's review of the proposal for acceptability and approved products will be set forth by the Addenda. If included in a Bid are substitute products which have not been approved by Addenda, the specified products shall be provided without additional compensation.
2. Submittals which do not provide adequate data for the product evaluation will not be considered. The proposed substitution must meet all requirements of this section, including but not necessarily limited to, the following: Single source materials suppliers (if specified in Section 1.5); Underwriters' Laboratories Classified Acoustical performance; Panel design, size, composition, color, and finish; Suspension system component profiles and sizes; Compliance with the referenced standards.

1.3 REFERENCES

- A. American Society for Testing and Materials (ASTM):

1. ASTM A 1008 Standard Specification for Steel, Sheet, Cold Rolled, Carbon, Structural, High-Strength Low-Alloy and High-Strength Low-Alloy with Improved Formability.
 2. ASTM A 641 Standard Specification for Zinc-Coated (Galvanized) Carbon Steel Wire.
 3. ASTM A 653 Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) by the Hot-Dip Process.
 4. ASTM C 423 Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method.
 5. ASTM C 635 Standard Specification for Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings.
 6. ASTM C 636 Recommended Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels.
 7. ASTM E 84 Standard Test Method for Surface Burning Characteristics of Building Materials.
 8. ASTM E 1414 Standard Test Method for Airborne Sound Attenuation Between Rooms Sharing a Common Ceiling Plenum.
 9. ASTM E 1111 Standard Test Method for Measuring the Interzone Attenuation of Ceilings Systems.
 10. ASTM E 1264 Classification for Acoustical Ceiling Products.
 11. ASTM E 1477 Standard Test Method for Luminous Reflectance Factor of Acoustical Materials by Use of Integrating-Sphere Reflectometers.
 12. ASTM D 3273 Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber.
 13. ASTM E 119 Standard Test Methods for Fire Tests of Building Construction and Material.
- B. ASHRAE Standard 62.1-2004, "Ventilation for Acceptable Indoor Air Quality"
- C. International Code Council-Evaluation Services - AC 156 Acceptance Criteria for Seismic Qualification Testing of Non-structural Components
- D. International Code Council-Evaluation Services - Evaluation Report, ESR-1308, Fire- and Nonfire-Resistance-Rated Suspended Ceiling Framing Systems
- E. ASCE 7 Standard - American Society of Civil Engineers, Minimum Design Loads for Buildings and Other Structures
- F. CISCA 0-2 - Ceilings and Interior Systems Construction Association Recommendations for Direct-Hung Acoustical Tile and Lay-In Panel Ceilings, Seismic Zones 0-2

1.6 SYSTEM DESCRIPTION

- A. Seismic Loads: Design and size components to withstand seismic loads in accordance with the International Building Code, Section 1621 for Category C.

1.5 SUBMITTALS

- A. Product Data: Submit manufacturer's technical data for each type of acoustical ceiling unit and suspension system required.
- B. Samples: Minimum 6 inch x 6 inch samples of specified acoustical panel; 8 inch long samples of exposed wall molding and suspension system, including main runner and 4 foot cross tees.
- C. Shop Drawings: Layout and details of acoustical ceilings. Show locations of items which are to be coordinated with, or supported by the ceilings.
- D. Certifications: Manufacturer's certifications that products comply with specified requirements, including laboratory reports showing compliance with specified tests and standards. For acoustical performance, each carton of material must carry an approved independent laboratory classification of NRC, CAC, and AC.
- E. If the material supplied by the acoustical subcontractor does not have an Underwriter's Laboratory classification of acoustical performance on every carton, subcontractor shall be required to send material from every production run appearing on the job to an independent or NVLAP approved laboratory for testing, at the architect's or owner's discretion. All products not conforming to manufacturer's current published values must be removed, disposed of and replaced with complying product at the expense of the Contractor performing the work.

1.6 QUALITY ASSURANCE

- A. Single-Source Responsibility: Provide acoustical panel units and grid components by a single manufacturer.
- B. Fire Performance Characteristics: Identify acoustical ceiling components with appropriate markings of applicable testing and inspecting organization.
 - 1. Surface Burning Characteristics: As follows, tested per ASTM E 84 and complying with ASTM E 1264 for Class A products.
 - a. Flame Spread: 25 or less
 - b. Smoke Developed: 50 or less
- C. Seismic Performance: Provide acoustical ceiling system that has been evaluated by an independent party and found to be compliant with the 2003 International Building Code, Seismic Category C.
 - 1. Tested per International Code Council - Evaluation Services - AC 156 Acceptance Criteria for Seismic Qualification Testing of Non-structural Components as evidenced by International Code Council Evaluation Report, ESR-1308.

- D. Handle acoustical ceiling units carefully to avoid chipping edges or damaged units in any way.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Deliver acoustical ceiling units to project site in original, unopened packages and store them in a fully enclosed space where they will be protected against damage from moisture, direct sunlight, surface contamination, and other causes.
- B. Before installing acoustical ceiling units, permit them to reach room temperature and a stabilized moisture content.
- C. Handle acoustical ceiling units carefully to avoid chipping edges or damaged units in any way.

1.8 PROJECT CONDITIONS

- A. Space Enclosure:

All ceiling products and suspension systems must be installed and maintained in accordance with Armstrong written installation instructions for that product in effect at the time of installation and best industry practice. Prior to installation, the ceiling product must be kept clean and dry, in an environment that is between 32°F (0°C) and 120°F (49°C) and not subject to Abnormal Conditions.

Abnormal conditions include exposure to chemical fumes, vibrations, moisture from conditions such as building leaks or condensation, excessive humidity, or excessive dirt or dust buildup.

HumiGuard Plus Ceilings: Installation of the products shall be carried out where the temperature is between 32°F (0° C) and 120°F (49° C). It is not necessary for the area to be enclosed or for HVAC systems to be functioning. All wet work (plastering, concrete, etc) must be complete and dry.

The ceilings must be maintained to avoid excessive dirt or dust buildup that would provide a medium for microbial growth on ceiling panels. Microbial protection does not extend beyond the treated surface as received from the factory, and does not protect other materials that contact the treated surface such as supported insulation materials.

1.9 WARRANTY

- A. Acoustical Panel: Submit a written warranty executed by the manufacturer, agreeing to repair or replace acoustical panels that fail within the warranty period. Failures include, but are not limited to:
 - 1. Acoustical Panels: Sagging and warping as a result of defects in materials or factory workmanship.
 - 2. Grid System: Rusting and manufacturer's defects
 - 3. Acoustical Panels with BioBlock Plus or designated as inherently resistive to the growth of micro-organisms installed with Armstrong suspension systems: Visible sag and will

resist the growth of mold/mildew and gram positive and gram negative odor and stain causing bacteria.

B. Warranty Period Humiguard:

1. Acoustical panels: Ten (10) years from date of substantial completion.
2. Grid: Ten (10) years from date of substantial completion.
3. Acoustical panels and grid systems with HumiGuard Plus or HumiGuard Max performance supplied by one source manufacturer is thirty (30) years from date of substantial completion.

C. The Warranty shall not deprive the Owner of other rights the Owner may have under other provisions of the Contract Documents and will be in addition to and run concurrent with other warranties made by the Contractor under the requirements of the Contract Documents.

1.10 MAINTENANCE

A. Extra Materials: Deliver extra materials to Owner. Furnish extra materials described below that match products installed. Packaged with protective covering for storage and identified with appropriate labels.

1. Acoustical Ceiling Units: Furnish quality of full-size units equal to 5.0 percent of amount installed.
2. Exposed Suspension System Components: Furnish quantity of each exposed suspension component equal to 2.0 percent of amount installed.

Part 2-PRODUCTS

2.1 MANUFACTURERS

A. Ceiling Panels:

1. Armstrong World Industries, Inc.

2.2 ACOUSTICAL CEILING UNITS

A. Acoustical Panels Type ACT-1:

1. Surface Texture: Fine
2. Composition: Mineral Fiber
3. Color: White
4. Size: 24in X 24in X 3/4in
5. Edge Profile: Beveled Tegal for interface with Prelude XL 15/16" Exposed Tee.

6. Noise Reduction Coefficient (NRC): ASTM C 423; Classified with UL label on product carton, 0.60.
7. Ceiling Attenuation Class (CAC): ASTM C 1414; Classified with UL label on product carton, 40
8. Emissions Testing: Section 01350 Protocol, < 13.5 ppb of formaldehyde when used under typical conditions required by ASHRAE Standard 62.1-2004, "Ventilation for Acceptable Indoor Air Quality"
9. Flame Spread: ASTM E 1264; Class A (UL)
10. Light Reflectance (LR): ASTM E 1477; White Panel: Light Reflectance: 0.90.
11. Dimensional Stability: HumiGuard Plus - Temperature is between 32°F (0° C) and 120°F (49° C). It is not necessary for the area to be enclosed or for HVAC systems to be functioning. All wet work (plastering, concrete, etc) must be complete and dry.
12. Antimicrobial Protection: BioBlock Plus - Resistance against the growth of mold/mildew and gram positive and gram negative odor and stain causing bacteria.
13. Acceptable Product: Ultima High CAC, 1951 as manufactured by Armstrong World Industries.

2.3 SUSPENSION SYSTEMS

- A. Components: Main beams and cross tees In accordance with the International Building Code, Section 1621 for Category C as described in ESR-1308.
 1. Structural Classification: ASTM C 635, (Intermediate Duty) (Heavy Duty).
 2. Color: White and match the actual color of the selected ceiling tile, unless noted otherwise.
 3. Represented Systems: Prelude XL 15/16" Exposed Tee System as manufactured by Armstrong World Industries.
- B. Attachment Devices: In accordance with the International Building Code, Section 1621 for Category C.
- C. Wire for Hangers and Ties: In accordance with the International Building Code, Section 1621.
- D. Wall Moldings: In accordance with the International Building Code, Section 1621 for Category C or method as described in ESR-1308.
 1. Nominal 7/8 inch x 7/8 inch hemmed, pre-finished angle molding (7800) (7802) (7803) (780036) (HD7801)
 2. Nominal 15/16 inch x 15/16 inch hemmed, pre-finished angle molding (7809)
 3. Nominal 3/4 inch x 15/16 inch x 3/4 inch hemmed, pre-finished shadow molding (7871)
 4. Nominal 9/16 inch x 15/16 inch x 3/8 inch hemmed, pre-finished shadow molding (7873)

5. Nominal 9/16 inch x 15/16 inch x 1/4 inch hemmed, pre-finished shadow molding (7874)
 6. Nominal 3/4 inch x 15/16 inch x 1/2 inch hemmed, pre-finished shadow molding (7875)
- E. Accessories:
1. BERC - Beam End Retaining Clip, 0.034 inch thick, hot-dipped galvanized cold-rolled steel ASTM A568 - used to join main beam or cross tee to wall molding.
 2. BERC2 - 2 inch Beam End Retaining Clip, 0.034 inch thick, hot-dipped galvanized cold-rolled steel per ASTM A568 - used to join main beam or cross tee to wall molding.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Do not proceed with installation until all wet work such as concrete, terrazzo, plastering and painting has been completed and thoroughly dried out, unless expressly permitted by manufacturer's printed recommendations. (Exception: HumiGuard Max Ceilings)

3.2 PREPARATION

- A. Measure each ceiling area and establish layout of acoustical units to balance border widths at opposite edges of each ceiling. Avoid use of less than half width units at borders, and comply with reflected ceiling plans. Coordinate panel layout with mechanical and electrical fixtures.
- B. Coordination: Furnish layouts for preset inserts, clips, and other ceiling anchors whose installation is specified in other sections.
1. Furnish concrete inserts and similar devices to other trades for installation well in advance of time needed for coordination of other work.

3.3 INSTALLATION (Category C)

- A. Install suspension system and panels in accordance with the International Building Code, Section 1621, except as noted in Section 4.4.3.2 of ESR-1308, and with the authorities having jurisdiction.
- B. ESR-1308, Section 4.4.3.2, Seismic Design Category C Installation:

Terminal ends of the runners are secured by attaching the BERC clip to the wall molding and attaching the runners to the BERC clip. The runners have zero clearance at the perimeter on two adjacent walls and with 3/8-inch (9.5 mm) clearance on the opposite walls. The clip is attached to the wall molding by sliding the locking lances over the hem of the vertical leg of the wall molding. BERC clips installed in this manner are an acceptable means of preventing runners from spreading, in lieu of spacer bars required in CISCA 0-2, which is referenced in ASCE 7, Section 9.6.2.6.2.1, which is referenced in IBC Section 1621. Except for the use of the BERC clip as noted above, installation of the ceiling system must be as prescribed by the

applicable code. Maximum ceiling weight permitted is 3.35 pounds per square foot (16.35 kg/m²). This construction is equivalent to that required by CISCA 0-2, which is referenced in ASCE-7, Section 9.2.6.2.1, and which is referenced in IBC Section 1621.

Alternate #2: If Acceptable to architect, fixed attachment may be accomplished by pop-riveting the runner to the wall molding.

- C. The presence of a hanger wire within 3 inches of an expansion relief joint as called for in ASTM C 636 shall be required in addition to the requirements of the International Building Code, Section 1621.2.5 and with the authorities having jurisdiction.
 - 1. Only applies when using (Prelude XL Fire Guard 15/16") (Prelude Plus XL Fire Guard 15/16") (Suprafine XL Fire Guard 9/16") Exposed Tee Systems.
- D. For reveal edge panels: Cut and reveal or rabbet edges of ceiling panels at border areas and vertical surfaces.
- E. Install acoustical panels in coordination with suspended system, with edges resting on flanges of main runner and cross tees. Cut and fit panels neatly against abutting surfaces. Support edges by wall moldings.

3.4 ADJUSTING AND CLEANING

- A. Replace damaged and broken panels.
- B. Clean exposed surfaces of acoustical ceilings, including trim, edge moldings, and suspension members. Comply with manufacturer's instructions for cleaning and touch up of minor finish damage.
 - 1. Ceiling Touch-Up Paint, (Item #5760, 8oz. bottles) (Item #5761, quart size cans), "global white" latex paint should be used to hide minor scratches and nicks in the surface and to cover field tegularized edges that are exposed to view.
- C. Remove and replace work that cannot be successfully cleaned and repaired to permanently eliminate evidence of damage.

END OF SECTION 09 51 13