

ELECTRICAL SYMBOL LIST		ABBREVIATIONS	
LINE TYPES		SYMBOL DESCRIPTION	
-----	DARK DASHED LINE INDICATES DEMOLITION WORK	A, AMP	AMPERE
—————	LIGHT CONTINUOUS LINE INDICATES EXISTING TO REMAIN	AC	ALTERNATING CURRENT
—————	DARK CONTINUOUS LINE INDICATES NEW WORK IN CONTRACT	A/C	AIR CONDITIONER
WIRING AND CONDUIT		AFF	ABOVE FINISHED FLOOR
PP#(1,3,5) PP#(1,3) PP#1	CONCEALED HOME RUN TO PANELBOARD OR SWITCHBOARD. NOTATION INDICATES PANEL DESIGNATION AND CIRCUIT(S) NUMBER. No. OF ARROWS DENOTES No. OF CIRCUITS: 2#12, 1#12G, 3/4"C. (U.O.N.).	AFI	ARC FAULT INTERRUPTER
PP#1,3	EX: PP#1: PANEL PP, CIRCUIT #1 (SINGLE POLE OCPD) PP#1,3: PANEL PP, CIRCUITS #1 & #3 (SINGLE POLE OCPD) PP#(1,3): PANEL PP, CIRCUITS #1 & #3 (TWO POLE OCPD) PP#1,3,5: PANEL PP, CIRCUITS #1, #3 & #5 (SINGLE POLE OCPD) PP#(1,3,5): PANEL PP, CIRCUITS #1, #3 & #5 (THREE POLE OCPD)	AF/AT	AMPERE FRAME/AMPERE TRIP
PP#1,3,5		AIC	AMPERES INTERRUPTING CAPACITY
	CONCEALED WIRING AND CONDUIT RUN. 2#12, 1#12G, 3/4"C. (U.O.N.)	ARCH	ARCHITECTURAL
	CONTINUATION OF WIRING AND CONDUIT RUN. 2#12, 1#12G, 3/4"C. (U.O.N.)	AS/AF	AMPERE SWITCH/AMPERE FUSE
	EMPTY CONDUIT WITH DRAG LINE. PROVIDE RUBBER GROMMETS AT BOTH ENDS WHEN USED FOR LOW VOLTAGE WIRING (COMMUNICATION, SECURITY, ETC)	ATS	AUTOMATIC TRANSFER SWITCH
	CONDUIT RUNNING UP	A/V	AUDIO/VISUAL
	CONDUIT RUNNING DOWN	AWG	AMERICAN WIRE GAUGE
		BLDG	BUILDING
		BLR	BOILER
		BMS	BUILDING MANAGEMENT SYSTEM
		C, CDT	CONDUIT
		CB	CIRCUIT BREAKER
		CELL	CELLAR
		CKT(S)	CIRCUIT(S)
		CL	CLOSET
		CLG	CEILING
		CO	CERTIFICATE OF OCCUPANCY
		CONV	CONVENIENCE
		C/T	CURRENT TRANSFORMER
		CU	COPPER
		DGP	DATA GATHERING PANEL
		DISC	DISCONNECT
		DIST	DISTRIBUTION
		DN	DOWN
		DWG	DRAWING
		EC	EMPTY CONDUIT
		ELEC	ELECTRIC
		ELEV	ELEVATOR
		EM	EMERGENCY
		EM/NL	EMERGENCY/NIGHT LIGHT
		EMT	ELECTRIC METALLIC TUBING
		EQUIP	EQUIPMENT
		ER	EXISTING TO RELOCATE
		ETC	ETCETERA
		EXIST	EXISTING
		FA	FIRE ALARM
		FBO	FURNISHED BY OTHERS
		FL	FLOOR
		FMC	FLEXIBLE METALLIC TUBING
		G, GND	GROUND
		GA	GAUGE
		GFI	GROUND FAULT INTERRUPTER
		GWB	GYPSUM WALL BOARD
		HP	HORSEPOWER
		IG	ISOLATED GROUND

PROGRESS
11-02-2011